

StanfordNews

<http://news.stanford.edu>



AMERICAN METEOROLOGICAL SOCIETY NEWS RELEASE

FOR IMMEDIATE RELEASE
November 20, 2007

Contact(s): Stephanie Kenitzer, AMS
(425) 432-2192
Kenitzer@dc.ametsoc.org

Louis Bergeron, News Service
(650) 725-1944,
louisb3@stanford.edu

The Power of Multiples: Connecting Wind Farms Can Make A More Reliable – and Cheaper – Power Source

Wind power, long considered to be as fickle as wind itself, can be groomed to become a steady, dependable source of electricity and delivered at a lower cost than at present, according to scientists at Stanford University.

The key is connecting wind farms throughout a given geographic area with transmission lines, thus combining the electric outputs of the farms into one powerful energy source. The findings are published in the November issue of the American Meteorological Society's *Journal of Applied Meteorology and Climatology*.

Wind is the world's fastest growing electric energy source, according to the study's authors, Cristina Archer and Mark Jacobson. However, because wind is intermittent, it is not used to supply baseload electric power today. Baseload power is the amount of steady and reliable electric power that is constantly being produced, typically by power plants, regardless of the electricity demand. But interconnecting wind farms with a transmission grid reduces the power swings caused by wind variability and makes a significant portion of it just as consistent a power source as a coal power plant.

“This study implies that, if interconnected wind is used on a large scale, a third or more of its energy can be used for reliable electric power, and the remaining intermittent portion can be used for transportation, allowing wind to solve energy, climate and air pollution problems simultaneously,” said Archer, the study’s lead author and a consulting assistant professor in Stanford’s Department of Civil and Environmental Engineering and research associate in the Department of Global Ecology of the Carnegie Institution.

It’s a bit like having a bunch of hamsters generating your power, each in a separate cage with a treadmill. At any given time, some hamsters will be sleeping or eating and some will be running on their treadmill. If you have only one hamster, the treadmill is either turning or it isn’t, so the power’s either on or off. With two hamsters, the odds are better that one will be on a treadmill at any given point in time and your chances of running, say, your blender, go up. Get enough hamsters together and the odds are pretty good that at least a few will always be on the treadmill, cranking out the kilowatts.

The combined output of all the hamsters will vary, depending on how many are on treadmills at any one time, but there will be a certain level of power that is always being generated, even as different hamsters hop on or off their individual treadmills. That’s the reliable baseload power.

The connected wind farms would operate the same way.

“The idea is that, while wind speed could be calm at a given location, it could be gusty at others. By linking these locations together we can smooth out the differences and substantially improve the overall performance,” Archer said.

As one might expect, not all locations make sense for wind farms. Only locations with strong winds are economically competitive. In their study, Archer and Jacobson, a professor of civil and environmental engineering at Stanford, evaluated 19 sites in the Midwestern United States, with annual average wind speeds greater than 6.9 meters per second at a height of 80 meters above ground, the hub height of modern wind turbines. Modern turbines are 80-100 meters high, approximately the height of a 30-story building, and their blades are 70 meters long or more.

The researchers used hourly wind data, collected and quality-controlled by the National Weather Service, for the entire year of 2000 from the 19 sites in the Midwestern United States. They found that an average of 33 percent and a maximum of 47 percent of yearly-averaged wind power from interconnected farms can be used as reliable, baseload electric power. These percentages would hold true for any array of 10 or more wind farms, provided it met the minimum wind speed and turbine height criteria used in the study.

Another benefit of connecting multiple wind farms is reducing the total distance that all the power has to travel from the multiple points of origin to the destination point. Interconnecting multiple wind farms to a common point and then connecting that point to a far-away city reduces the cost of transmission.

It's the same as having lots of streams and creeks join together to form a river that flows out to sea, rather than having each creek flow all the way to the coast by carving out its own little channel.

Another type of cost saving also results when the power combines to flow in a single transmission line. Explains Archer: Suppose a power company wanted to bring power from several independent farms—each with a maximum capacity of, say, 1,500 kilowatts (kW) —from the Midwest to California. Each farm would need a short transmission line of 1,500 kW brought to a common point in the Midwest. Then they would need a larger transmission line between the common point and California—typically with a total capacity of 1,500 kW multiplied by the number of independent farms connected.

However, with geographically dispersed farms, it is unlikely that they would simultaneously be experiencing strong enough winds to each produce their 1,500kW maximum output at the same time. Thus, the capacity of the long-distance transmission line could be reduced significantly with only a small loss in overall delivered power.

The more wind farms connected to the common point in the Midwest, the greater the reduction in long-distance transmission capacity that is possible.

“Due to the high cost of long-distance transmission, a 20 percent reduction in transmission capacity with little delivered power loss would notably reduce the cost of wind energy,” added Archer, who calculated the decrease in delivered power to be only about 1.6 percent.

With only one farm, a 20 percent reduction in long-distance transmission capacity would decrease delivered power by 9.8 percent—not a 20 percent reduction, because the farm is not producing its maximum possible output all the time.

Archer said that if the United States and other countries each started to organize the siting and interconnection of new wind farms based on a master plan, the power supply could be smoothed out and transmission requirements could be reduced, decreasing the cost of wind energy. This could result in the large-scale market penetration of wind energy—already the most inexpensive clean renewable electric power source—which could contribute significantly to an eventual solution to global warming, as well as reducing deaths from urban air pollution.

The American Meteorological Society (www.ametsoc.org) is the nation's leading professional organization for those involved in the atmospheric and related sciences. Founded in 1919, the AMS has more 11,000 international members, organizes nearly a dozen scientific conferences annually, and publishes nine peer-reviewed journals.

###

Editor's Note: You may contact authors Cristina L. Archer at (650) 462-1047 or lozej@stanford.edu and Mark Jacobson at (650) 723-6836 or Jacobson@stanford.edu. A copy of the paper is online at http://www.stanford.edu/group/efmh/winds/aj07_jam.pdf